



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
ZONAL WATER TESTING LABORATORY, SIRSA

E-mail:-Seniorchemist.phedharyana@gmail.com



TC-11949

Test Report No : - SIR/04452		Test Report	
Issue To - J K Memorial Public School		Issue Date -23/02/2024	
Your Reference No- By Hand Dt. 08/02/2024		Location- R O Water From J K Memorial public school, Odhan	
Sample Type -R O Water		Collected By - Sh.	
Lab Job Order No.- PC - 1972684		Sample Collected Date -13/02/2024	
Period of Analysis - 13/02/2024		Sample Received Date -13/02/2024	
Environmental Condition :-	Temp 25 ± 2 °C,	Humidity 55 ± 15 %	

S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solid	APHA 2540 C 2017 23rd Edition-2017	58	500	2000	mg/L
2	Total Hardness (as CaCo3)	APHA 23rd Edition 2340 C: 2017	10	200	600	mg/L
3	Calcium (as Ca)	APHA 23rd Edition 3500- Ca B: 2017	0.00	75	200	mg/L
4	Magnesium (as Mg)	APHA 23rd Edition 3500 -Mg B:2017	2.43	30	100	mg/L
5	Total Alkalinity (as CaCo3)	APHA 23rd Edition 2320 B: 2017	40	200	600	mg/L
6	Chloride (as Cl)	APHA 23rd Edition 4500 -Cl- B: 2017	14.99	250	1000	mg/L
7	pH @ 25°C	APHA 23rd Edition 4500 -H+B:2017	7.98	6.5 -8.5	No relaxation	-
8	Turbidity	APHA 2130 B	0.17	1	5.0	NTU
9	Taste	IS3025 (Part-8)	Agreeable	Agreeable	Agreeable	Qualitative
10	Odour	IS3025 (Part-5)	Agreeable	Agreeable	Agreeable	Qualitative

Remarks:- The Parameter Tested at Sr.No 1-10 as per requirement of IS:10500:2012 Second Revision(RA 2018).

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Sirsa Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
- The above parameter are tested for drinking purpose

Sample analyzed by

(Santosh Kumari)

Authorized Signatory/ Senior Chemist
PHED Zonal Water Testing Laboratory, Sirsa



**OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
ZONAL WATER TESTING LABORATORY, SIRSA**

E-mail:-Seniorchemist.phedharyana@gmail.com



Test Report	
Test Report No : - SIR/04452	Issue Date -23/02/2024
Issue To - J K Memorial Public School	Location- R O Water From J K Memorial public school, Odhan
Your Reference No- By Hand Dt. 08/02/2024	Collected By - Sh.
Sample Type -R O Water	Sample Collected Date -13/02/2024
Lab Job Order No.- PC - 1972684	Sample Received Date -13/02/2024
Period of Analysis - 13/02/2024	Sample Quantity - 1 Ltr
Environmental Condition :- Temp 25 ± 2 °C, Humidity 55 ± 15 %	

S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
				11	Iron	
12	Sulphate	APHA 4500 E 23rd Edition-2017	8	200	400	mg/L
13	Fluoride (as F)	APHA 4500-F D,C:2017 23rd Edition-2017	0.102	1.0	1.5	mg/L
14	Nitrate (as NO ₃)	APHA4500 -NO ₃ - D :2017 23rd Edition-2017	0.5	45	No relaxation	mg/L
15	Color	APHA 2120 C; 2017	<5	5 Hazen Units	15 Hazen Units	Hazen Units
16	RCl	IS3025 (Part-26)	0.0	0.2	1.0	mg/L

Remarks:- The Parameter Tested at Sr.No 11-16 as per requirement of IS:10500:2012 Second Revision(RA 2018).

- Notes:**
- The results given above are related to the sample as received and tested in PHED Lab, Sirsa Reliability of sample lies with the sender.
 - The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
 - The test report can't be used for any publicity or any legal purpose.
 - The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.
 - The above parameter are tested for drinking purpose

Sample analyzed by

(Santoshi Kumari)

Authorized Signatory/ Senior Chemist
PHED Zonal Water Testing Laboratory, Sirsa